

FIRE SAFETY CERTIFICATE

No. 867

Dated: 29/01/2024

Certified that the **BISHOP ACADEMY** (name of the building or premises) at **Dhanewa-Dhanei, Nichloul Road, Maharajganj** (address) comprised of 0 basement(s) and 3 (upper floors) owned/ occupied by **BISHOP ACADEMY Dhanewa-Dhanei, Nichloul Road, Maharajganj** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on **29/01/2024** (date of inspection) in the presence of **VIRENDRA KUMAR TIWARI, HIG 18, Shashtripuram, Gorakhnath, Gorakhpur** (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes Pre Primary to XII (X/ XII) with effect from **29/01/2024** for a period of **3 years** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Fire audit should be done at least once in 2 years from the Adhikari/Fire Engineer and certificate of working of fire fighting system should be obtained in January and July of the year and sent to the department.
2. Ten year old fire extinguishers should not be used and new fire extinguishers should always be kept in working condition.
3. It would be desirable to keep all the provisions as per the map of the building approved by the designated authority.
4. Departmental approval should be taken for the pandal to be set up in the annual function in the school and for the construction of additional building
5. FSSO should participate in mock drill from time to time and keep inspecting it.
6. Issued as per the order dated 07.01.22

Issued on 29/01/24 (Date of issue) at Maharajganj (Place) by

Signature with Seal: J Singh
29/01/24

Name : **JASVEER SINGH**

मुख्य अग्निशमन अधिकारी
महाराजगंज

Designation : **CHIEF FIRE OFFICER**

Name & Address of Department/ Office:

Fire Station Maharajganj

To

Bishop Academy

Dhanewa-Dhanei, Nichloul Road, Maharajganj

(Name & Address of the Institution)